



TRINITY METRO®

February 11, 2026

ADDENDUM #4

THIS ADDENDUM IS ISSUED TO:

RFP 26-T016- Facilities Generator Project

Purpose: Answer to vendor submitted questions

Answers in Red

1. How many gallons of fuel or how many hours of run time do you want for the (2) generators?

The generator system shall be provided with onsite fuel storage sufficient for a minimum of thirty (30) continuous hours of operation at seventy-five percent (75%) of the generator's standby nameplate rating, unless otherwise approved by the Owner.

2. Will the contractor be required to provide temporary power to the facility during the generator project?

Yes. See the revised Scope of Work requirements below.

"Scope of Work, **Section 5, D, Temporary Electrical Service**, is hereby amended to include the following:

The contractor shall be responsible for coordinating project construction phasing with the owner, to minimize impact on owner's day to day operations at the facility. The contractor shall include in his bid a line item for temporary power to maintain facility operation during all phases of construction. The contractor shall coordinate with the owner locations for any required temporary generator(s) and associated gear and cabling prior to installation on site. The contractor shall be responsible for fuel for temporary generators during operation. As part of project

completion, the contractor shall restore all surfaces and landscaping to present condition, or better, after the removal of any temporary generators and associated temporary equipment.”

ALL TERMS OF THE REQUEST FOR PROPOSAL REMAIN THE SAME UNLESS CHANGED THROUGH A WRITTEN AMENDMENT TO THE REQUEST FOR PROPOSAL. NO ORAL CHANGES ARE BINDING. CHANGE REQUESTS MUST BE IN THE FORM OF A WRITTEN REQUEST TO BE ANSWERED IN A WRITTEN ADDENDUM.

RESPONDENTS MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE FORM 1 IN THEIR PROPOSAL. FAILURE TO DO SO MAY INVALIDATE THE PROPOSAL.

End of Addendum # 4